

PERFORMANCE PARAMETER FOR THE MONTH OF OCTOBER-NOVEMBER-DECEMBER-2019

Sr. No.	Power Station	PAF (%)			PLF (%)			SHR as Fired (Kcal/Kwh)			Auxi. Consumption (%)			SFC (Kg./Kwh)			Actual Gross Generation (Mus)			Net Generation (Mus)		
		Oct	Nov	Dec	Oct	Nov	Dec	Oct	Nov	Dec	Oct	Nov	Dec	Oct	Nov	Dec	Oct	Nov	Dec	Oct	Nov	Dec
1	Ukai (3-5)	99.44%	93.50%	92.95%	42.49%	41.57%	69.79%	2613	2563	2606	10.76%	10.50%	9.74%	4.12	2.22	1.04	192.85	182.57	316.74	172.10	163.39	285.90
2	Ukai Extn. 6	88.19%	78.26%	96.02%	61.97%	62.72%	77.98%	2372	2351	2338	6.97%	6.56%	5.70%	1.62	0.79	0.34	230.52	225.80	290.09	214.46	210.99	273.55
3	Gandhinagar (3-4)	99.42%	99.42%	99.42%	0.87%	1.81%	5.25%	3083	2947	2698	64.63%	29.60%	20.84%	23.20	26.37	11.69	2.71	5.48	16.42	0.96	3.86	12.99
4	Gandhinagar 5	101.31%	101.03%	3.26%	15.85%	20.34%	0.00%	2601	2616	0	16.55%	14.18%	0.00%	4.76	2.34	0.00	24.76	30.76	0.00	20.66	26.40	-0.71
5	Wanakbori 1-6	97.70%	86.64%	101.58%	6.05%	9.38%	36.25%	2507	2612	2520	16.32%	13.54%	9.74%	5.59	7.52	2.39	56.71	85.11	339.79	47.45	73.58	306.69
6	Wanakbori 7	100.98%	101.11%	97.78%	21.35%	26.78%	54.33%	2530	2484	2470	14.04%	11.62%	9.86%	6.16	2.89	1.20	33.36	40.50	84.88	28.68	35.79	76.51
7	Wanakbori 8	100.45%	27.80%	0.00%	57.86%	18.20%	0.00%	2156	2140	0	6.29%	11.10%	0.00%	0.03	3.24	0.00	211.09	104.82	0.00	197.80	93.18	-1.39
8	Sikka Extn. (3-4)	98.64%	100.24%	60.37%	53.69%	70.82%	49.50%	2488	2464	2439	9.96%	9.22%	9.03%	2.34	1.51	0.08	199.74	254.97	184.16	179.85	231.47	167.53
9	KLTPS 1-3	12.04%	30.64%	30.71%	10.90%	30.76%	30.78%	3360	3237	3219	21.27%	14.34%	14.00%	19.18	2.00	1.27	17.43	47.61	49.23	13.72	40.78	42.34
10	KLTPS 4	57.99%	52.40%	58.73%	64.10%	58.19%	64.56%	3166	3149	3119	21.77%	21.98%	21.09%	2.59	1.29	0.66	35.77	31.42	36.03	27.98	24.52	28.43
11	BLTPS 1&2	7.08%	12.87%	29.68%	8.11%	14.05%	29.27%	3478	3350	3246	32.95%	21.93%	17.43%	9.15	3.14	1.38	30.17	50.58	108.88	20.23	39.49	89.90
12	Dhuvaran CCPP 1	97.08%	91.30%	85.40%	57.25%	29.80%	29.44%	2058	2137	2155	5.35%	7.61%	7.37%	-	-	-	45.41	22.87	23.35	42.98	21.13	21.63
13	Dhuvaran CCPP 2	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.32	-0.32	-0.26
14	Dhuvaran CCPP 3	0.00%	64.08%	87.59%	0.00%	30.97%	16.65%	0	2001	1983	6.90%	3.95%	4.12%	-	-	-	0.00	83.85	46.58	-0.39	80.54	44.66
15	Utran Extension	99.37%	94.60%	98.36%	43.56%	33.70%	22.80%	1802	1808	1830	3.03%	3.36%	4.03%	-	-	-	121.39	90.89	63.53	117.71	87.84	60.97
16	Ukai Hydro	96.69%	78.67%	73.91%	54.51%	41.75%	19.79%	-	-	-	0.65%	0.68%	0.83%	-	-	-	123.69	91.69	44.90	122.89	91.07	44.53
17	Kadana Hydro	85.44%	94.96%	94.13%	52.96%	8.16%	12.76%	-	-	-	0.64%	0.75%	0.73%	-	-	-	95.36	14.22	22.97	94.75	14.11	22.81