

PERFORMANCE PARAMETER FOR THE MONTH OF JULY-AUGUST-SEPTEMBER-2019

Sr. No.	Power Station	PAF (%)			PLF (%)			SHR as Fired (Kcal/Kwh)			Auxi. Consumption (%)			SFC (Kg./Kwh)			Actual Gross Generation (Mus)			Net Generation (Mus)		
		July	August	Sept	July	August	Sept	July	August	Sept	July	August	Sept	July	August	Sept	July	August	Sept	July	August	Sept
1	Ukai (3-5)	94.61%	36.26%	100.11%	73.20%	24.03%	12.50%	2610	2587	2580	9.83%	11.00%	14.76%	0.69	6.43	8.32	332.21	109.05	54.89	299.56	97.06	46.78
2	Ukai Extn. 6	16.33%	42.64%	101.26%	13.20%	39.15%	53.26%	2377	2328	2359	9.59%	6.60%	7.09%	0.00	1.95	0.87	49.10	145.64	191.72	44.39	136.06	178.14
3	Gandhinagar (3-4)	99.37%	99.42%	99.42%	23.77%	7.65%	0.00%	2585	2666	0	12.42%	19.34%	0.00%	1.72	6.32	0.00	74.28	23.91	0.00	65.06	19.29	-0.88
4	Gandhinagar 5	101.80%	101.77%	102.08%	86.51%	67.19%	0.00%	2546	2564	0	9.87%	10.20%	0.00%	0.00	1.34	0.00	135.16	104.97	0.00	121.82	94.27	-1.62
5	Wanakbori 1-6	98.32%	88.28%	100.56%	43.19%	30.29%	3.37%	2555	2516	2594	9.67%	10.42%	21.80%	1.36	3.01	2.69	404.90	283.99	30.61	365.74	254.41	23.93
6	Wanakbori 7	101.11%	101.04%	101.04%	84.58%	85.37%	25.01%	2452	2455	2462	9.70%	9.73%	12.02%	0.00	0.17	0.74	132.14	133.38	37.81	119.32	120.20	33.27
7	Sikka Extn. (3-4)	100.66%	94.79%	96.20%	76.57%	67.03%	11.98%	2471	2499	2561	9.29%	9.71%	15.75%	0.57	2.42	7.71	284.83	249.35	43.14	258.36	225.14	36.34
8	KLTPS 1-3	29.92%	21.91%	16.13%	29.79%	21.37%	16.82%	3334	3390	3389	16.05%	19.37%	20.11%	13.37	24.09	20.59	47.66	34.18	26.04	40.01	27.56	20.80
9	KLTPS 4	47.09%	15.55%	33.16%	51.05%	16.56%	36.07%	3130	3230	3140	22.00%	37.24%	24.93%	4.15	13.65	3.86	28.49	9.24	19.48	22.22	5.80	14.62
10	BLTPS 1&2	6.03%	4.44%	8.77%	6.87%	5.33%	10.17%	3632	3679	3505	36.00%	41.00%	31.00%	11.76	17.39	6.23	25.56	19.82	36.62	16.44	11.74	25.39
11	Dhuvaran CAPP 1	0.00%	81.62%	86.22%	0.00%	10.23%	34.38%	0	2491	2105	0.00%	12.07%	6.90%	-	-	-	0.00	8.12	26.39	-0.25	7.14	24.57
12	Dhuvaran CAPP 2	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.26	-0.28	-0.29
13	Dhuvaran CAPP 3	55.45%	92.84%	65.89%	6.14%	18.23%	17.85%	2110	1975	1950	10.08%	4.46%	5.07%	-	-	-	17.18	51.00	48.33	15.45	48.72	45.88
14	Utran Extension	75.69%	99.99%	99.99%	17.78%	9.42%	16.28%	1801	1982	1905	4.23%	6.89%	4.75%	-	-	-	49.54	26.24	43.91	47.44	24.43	41.82
15	Ukai Hydro	96.32%	96.99%	97.29%	0.00%	62.50%	98.62%	-	-	-	0.00%	0.64%	0.60%	-	-	-	0.00	141.82	216.57	-0.12	140.92	215.26
16	Kadana Hydro	79.01%	84.69%	78.31%	11.64%	49.25%	76.46%	-	-	-	0.69%	0.61%	0.61%	-	-	-	20.96	88.68	133.23	20.81	88.13	132.43