

## PERFORMANCE PARAMETER FOR THE MONTH OF JULY-AUGUST-SEPTEMBER-2020

Sr. No.	Power Station	PAF (%)			PLF (%)			SHR as Fired (Kcal/Kwh)			Auxi. Consumption (%)			SFC (Kg./Kwh)			Actual Gross Generation (Mus)			Net Generation (Mus)		
		JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER
1	Ukai (3-5)	98.54%	98.54%	87.67%	0.67%	1.10%	27.65%	2360	2428	2559	27.20%	20.86%	11.83%	0.30	10.63	12.11	3.04	4.99	121.43	1.41	3.30	107.07
2	Ukai Extn. 6	100.00%	99.19%	91.91%	6.86%	21.09%	74.13%	2428	2385	2349	18.64%	8.82%	6.41%	11.06	4.09	0.84	25.51	78.46	266.87	20.76	71.54	249.75
3	Gandhinagar (3-4)	99.42%	99.42%	98.68%	0.00%	0.00%	2.96%	0	0	2686	0.00%	0.00%	27.54%	0.00	0.00	12.07	0.00	0.00	8.96	-1.48	-1.45	6.49
4	Gandhinagar 5	100.00%	100.00%	100.00%	0.00%	0.00%	40.64%	0	0	2560	0.00%	0.00%	11.46%	0.00	0.00	2.53	0.00	0.00	61.46	-0.47	-0.41	54.41
5	Wanakbori 1-6	100.00%	100.00%	100.00%	0.00%	0.26%	9.13%	0	2774	2440	0.00%	0.00%	12.41%	0.00	34.40	3.86	0.00	2.41	82.81	-2.86	-0.68	72.53
6	Wanakbori 7	100.00%	77.22%	96.71%	0.00%	0.00%	7.24%	0	0	2516	0.00%	0.00%	16.30%	0.00	0.00	5.06	0.00	0.00	10.95	-0.52	-0.47	9.16
7	Wanakbori 8	100.00%	100.00%	60.71%	44.94%	16.20%	35.24%	2092	2082	2133	5.86%	8.43%	5.93%	0.88	0.02	1.84	267.48	96.45	203.00	251.80	88.32	190.96
8	Sikka Extn. (3-4)	72.67%	50.04%	96.22%	11.10%	11.59%	49.39%	2471	2493	2475	13.35%	13.91%	10.33%	3.77	5.97	2.69	41.28	43.10	177.79	35.77	37.10	159.43
9	KLTPS 3	71.83%	54.33%	73.05%	69.73%	52.22%	65.86%	3265	3267	3222	12.36%	12.96%	12.40%	6.07	10.43	2.22	38.91	29.14	35.57	34.10	25.36	31.16
10	KLTPS 4	43.96%	37.35%	37.41%	48.29%	40.35%	41.59%	3216	3165	3179	25.08%	24.88%	26.73%	5.70	4.72	10.69	26.95	22.51	22.46	20.19	16.91	16.46
11	BLTPS 1&2	34.80%	32.83%	10.15%	29.89%	6.56%	14.99%	3255	3653	3651	23.54%	49.88%	40.40%	5.89	42.06	27.34	111.20	24.42	53.98	85.03	12.24	32.17
12	Dhuvaran CCPP 1	81.80%	79.73%	82.57%	41.93%	10.40%	18.49%	2076	2230	2169	5.55%	10.35%	8.31%	-	-	-	33.26	8.25	14.19	31.41	7.39	13.01
13	Dhuvaran CCPP 2	75.06%	74.52%	78.45%	44.77%	22.09%	28.16%	2090	2230	2192	5.04%	7.50%	6.68%	-	-	-	37.45	18.48	22.80	35.56	17.10	21.28
14	Dhuvaran CCPP 3	0.00%	0.00%	63.48%	0.00%	0.00%	46.32%	0	0	1798	0.00%	0.00%	2.74%	-	-	-	0.00	0.00	125.43	-0.59	-0.61	121.99
15	Utran Extension	98.05%	59.59%	69.36%	73.06%	37.67%	50.92%	1721	1745	1742	2.21%	2.64%	2.47%	-	-	-	203.60	104.97	137.32	199.11	102.20	133.92
16	Ukai Hydro	73.48%	73.25%	73.88%	12.36%	44.23%	41.59%	-	-	-	0.97%	0.67%	0.67%	-	-	-	28.06	100.37	91.32	27.79	99.69	90.71
17	Kadana Hydro	89.67%	79.85%	84.08%	7.56%	25.45%	74.61%	-	-	-	0.85%	0.69%	0.62%	-	-	-	13.61	45.82	130.00	13.50	45.50	129.20