

PERFORMANCE PARAMETER FOR THE MONTH OF OCTOBER-NOVEMBER-DECEMBER-2020

Sr. No.	Power Station	PAF (%)			PLF (%)			SHR as Fired (Kcal/Kwh)			Auxil. Consumption (%)			SFC (Kg./Kwh)			Actual Gross Generation (Mus)			Net Generation (Mus)		
		OCTOBER	NOVEMBER	DECEMBER	OCTOBER	NOVEMBER	DECEMBER	OCTOBER	NOVEMBER	DECEMBER	OCTOBER	NOVEMBER	DECEMBER	OCTOBER	NOVEMBER	DECEMBER	OCTOBER	NOVEMBER	DECEMBER	OCTOBER	NOVEMBER	DECEMBER
1	Ukai (3-5)	94.70%	91.97%	87.07%	45.37%	31.39%	69.92%	2484	2497	2552	10.45%	10.95%	9.77%	4.01	3.84	1.84	205.90	137.85	317.31	184.38	122.75	286.32
2	Ukai Extn. 6	96.72%	99.72%	97.60%	80.98%	76.86%	80.64%	2362	2314	2355	6.21%	6.08%	5.60%	0.57	0.18	0.25	301.24	276.70	299.99	282.54	259.86	283.18
3	Gandhinagar (3-4)	99.42%	99.63%	100.00%	1.62%	0.01%	12.82%	2652	0	2585	31.68%	36.64%	12.64%	10.35	0.00	5.64	5.07	0.02	40.05	3.46	-0.86	34.99
4	Gandhinagar 5	100.00%	100.00%	99.96%	65.28%	34.01%	66.99%	2514	2552	2527	10.46%	12.21%	10.77%	0.00	2.91	1.21	102.00	51.42	104.67	91.34	45.14	93.40
5	Wanakbori 1-6	100.00%	100.00%	94.22%	12.99%	15.11%	37.63%	2362	2479	2524	11.20%	11.12%	9.49%	0.67	3.57	1.48	121.77	137.12	352.76	108.13	121.87	319.27
6	Wanakbori 7	99.77%	100.00%	97.23%	21.13%	34.57%	66.12%	2485	2471	2462	12.32%	10.40%	9.34%	2.85	1.78	0.54	33.02	52.28	103.30	28.95	46.84	93.65
7	Wanakbori 8	100.00%	100.00%	100.00%	79.05%	57.34%	74.95%	2107	2123	2131	4.52%	5.36%	4.78%	0.00	0.58	0.33	470.51	330.26	446.10	449.26	312.54	424.79
8	Sikka Extn. (3-4)	84.82%	100.00%	100.00%	73.18%	73.71%	84.67%	2459	2427	2404	9.84%	9.44%	8.89%	0.60	1.46	0.24	272.24	265.34	314.95	245.56	240.31	286.96
9	KLTPS 3	100.00%	95.77%	88.32%	96.83%	73.72%	83.51%	3191	3221	3184	11.19%	12.11%	12.72%	0.45	4.80	1.94	54.03	39.81	46.60	47.99	34.99	40.67
10	KLTPS 4	26.90%	52.21%	53.20%	29.74%	56.70%	57.98%	3214	3107	3059	31.38%	22.98%	22.11%	19.29	5.94	1.66	16.59	30.62	32.35	11.39	23.58	25.20
11	BLTPS 1&2	24.56%	40.85%	27.52%	27.85%	41.38%	29.13%	3263	3120	3185	23.02%	18.97%	21.07%	5.89	2.61	6.19	103.59	148.98	108.37	79.74	120.72	85.54
12	Dhuvaran CCPP 1	79.92%	78.79%	86.92%	68.57%	44.41%	31.48%	2088	2110	2054	4.99%	5.63%	5.45%	-	-	-	54.39	34.09	24.97	51.68	32.17	23.61
13	Dhuvaran CCPP 2	73.59%	76.27%	84.65%	62.25%	41.53%	29.72%	2122	2096	2118	4.68%	5.14%	5.33%	-	-	-	52.08	33.62	24.86	49.64	31.90	23.54
14	Dhuvaran CCPP 3	100.00%	65.64%	68.95%	81.93%	38.26%	33.91%	1752	1812	1802	2.22%	2.82%	2.75%	-	-	-	229.27	103.60	94.90	224.18	100.68	92.29
15	Utran Extension	96.90%	99.93%	85.08%	86.20%	71.00%	44.47%	1707	1752	1727	2.11%	2.39%	2.51%	-	-	-	240.22	191.49	123.93	235.16	186.92	120.82
16	Ukai Hydro	72.24%	72.24%	72.24%	40.41%	22.08%	15.25%	-	-	-	0.67%	0.76%	0.88%	-	-	-	91.69	48.49	34.61	91.08	48.13	34.40
17	Kadana Hydro	93.75%	95.31%	91.89%	12.79%	6.84%	12.58%	-	-	-	0.68%	0.65%	0.75%	-	-	-	23.03	11.92	22.66	22.87	11.84	22.53