

ANNEXURE-I PERFORMANCE PARAMETER FOR THE MONTH OF APRIL 20 to March 21													
Sr. No.	Power Station	PF (%)											
		April	May	June	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	March
1	Ukai (1-5)	96.00%	98.39%	98.54%	98.54%	98.54%	87.67%	94.70%	91.97%	87.07%	86.78%	74.95%	74.58%
2	Ukai Extn. 6	97.87%	71.49%	85.97%	100.00%	99.19%	91.91%	96.72%	99.72%	97.60%	85.19%	59.68%	41.57%
3	Gandhinagar (3-4)	99.42%	99.42%	99.42%	99.42%	99.42%	98.68%	99.42%	99.63%	100.00%	98.87%	99.68%	95.32%
4	Gandhinagar 5	100.00%	101.03%	101.03%	100.00%	100.00%	100.00%	100.00%	100.00%	99.96%	100.00%	99.71%	92.22%
5	Wanankori 1-6	101.00%	101.98%	101.98%	100.00%	100.00%	100.00%	94.22%	71.88%	79.64%	71.88%	79.64%	72.88%
6	Wanankori 7	100.00%	101.11%	101.11%	100.00%	77.22%	96.71%	99.77%	100.00%	97.23%	97.94%	89.53%	86.90%
7	Wanankori 8	100.00%	100.04%	98.58%	100.00%	100.00%	60.71%	100.00%	100.00%	100.00%	90.25%	81.08%	54.60%
8	Sikka Extn. (3-4)	100.00%	101.10%	80.04%	72.67%	50.04%	96.22%	84.82%	100.00%	100.00%	51.46%	51.01%	52.06%
9	KLTPS 3	86.46%	99.57%	75.75%	71.83%	54.33%	73.05%	100.00%	95.77%	88.32%	73.96%	3.25%	95.98%
10	KLTPS 4	44.40%	40.84%	51.76%	43.96%	37.85%	37.41%	26.90%	52.21%	53.20%	30.36%	50.57%	45.78%
11	BLTPS 1&2	22.27%	40.68%	28.11%	34.80%	32.83%	10.15%	24.56%	40.85%	27.52%	16.86%	20.63%	31.61%
12	Dhuvaran CCP1	84.68%	83.82%	65.88%	81.80%	79.73%	82.57%	79.92%	78.79%	86.92%	85.21%	89.51%	17.24%
13	Dhuvaran CCP2	77.53%	79.78%	73.04%	75.06%	74.52%	78.45%	73.59%	76.27%	84.65%	85.03%	88.90%	80.13%
14	Dhuvaran CCP3	85.19%	57.23%	0.00%	0.00%	0.00%	63.48%	100.00%	65.64%	68.95%	97.21%	100.00%	97.75%
15	Utran Extension	96.50%	80.61%	99.65%	98.05%	99.59%	49.36%	96.90%	99.93%	85.08%	95.32%	89.16%	85.81%
16	Ukai Hydro	73.77%	73.60%	73.33%	73.48%	73.25%	73.88%	72.24%	72.24%	72.24%	72.24%	92.89%	96.32%
17	Kadana Hydro	91.52%	94.82%	95.44%	89.67%	79.85%	84.08%	93.75%	95.31%	91.89%	90.65%	91.02%	90.57%

Sr. No.	Power Station	PLF (%)											
		April	May	June	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	March
1	Ukai (1-5)	22.78%	27.54%	24.83%	0.67%	1.10%	27.65%	45.37%	31.39%	69.92%	78.94%	71.91%	71.20%
2	Ukai Extn. 6	68.97%	61.48%	41.74%	6.86%	21.09%	74.13%	80.98%	76.86%	80.64%	76.39%	53.79%	43.07%
3	Gandhinagar (3-4)	0.00%	0.00%	0.00%	0.00%	0.00%	2.96%	1.62%	0.01%	12.82%	58.11%	84.60%	86.05%
4	Gandhinagar 5	0.00%	0.00%	0.00%	0.00%	0.00%	40.64%	65.28%	34.01%	66.99%	88.86%	90.39%	86.51%
5	Wanankori 1-6	44.40%	40.84%	51.76%	43.96%	37.85%	37.41%	26.90%	52.21%	53.20%	30.36%	50.57%	45.78%
6	Wanankori 7	0.00%	0.00%	0.00%	0.00%	0.00%	7.24%	21.13%	34.57%	66.12%	83.93%	80.92%	81.95%
7	Wanankori 8	38.62%	16.86%	12.58%	44.94%	16.20%	35.24%	79.05%	57.34%	74.95%	78.07%	75.58%	52.53%
8	Sikka Extn. (3-4)	0.00%	0.00%	63.42%	11.10%	11.59%	49.39%	73.18%	73.71%	84.67%	43.28%	44.94%	48.69%
9	KLTPS 3	84.19%	95.96%	73.86%	69.73%	52.22%	65.86%	96.83%	73.72%	82.51%	73.57%	3.24%	94.21%
10	KLTPS 4	69.18%	45.92%	85.07%	73.06%	37.67%	50.92%	86.20%	71.09%	44.47%	7.09%	16.15%	36.35%
11	BLTPS 1&2	25.67%	44.97%	30.73%	29.89%	6.56%	14.99%	27.85%	41.38%	29.13%	18.89%	23.47%	35.22%
12	Dhuvaran CCP1	69.03%	73.79%	58.82%	41.93%	10.40%	18.49%	68.57%	44.41%	31.48%	3.61%	14.66%	2.72%
13	Dhuvaran CCP2	36.76%	38.89%	58.62%	44.77%	22.09%	28.16%	62.25%	41.53%	29.72%	3.60%	7.54%	37.54%
14	Dhuvaran CCP3	60.01%	32.37%	0.00%	0.00%	0.00%	46.32%	81.93%	38.26%	32.91%	0.00%	8.67%	48.51%
15	Utran Extension	69.18%	45.92%	85.07%	73.06%	37.67%	50.92%	86.20%	71.09%	44.47%	7.09%	16.15%	36.35%
16	Ukai Hydro	28.29%	24.54%	12.50%	12.36%	44.23%	41.59%	40.41%	22.08%	15.25%	11.44%	27.89%	29.11%
17	Kadana Hydro	6.55%	3.44%	1.49%	7.56%	25.45%	74.61%	12.79%	6.84%	12.58%	15.63%	14.78%	11.31%

Sr. No.	Power Station	SHR as Fired (Kcal/Kwh)											
		April	May	June	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	March
1	Ukai (1-5)	2354	2344	2347	2360	2428	2555	2484	2497	2552	2555	2579	2652
2	Ukai Extn. 6	2354	2367	2352	2428	2385	2349	2362	2314	2355	2346	2370	2437
3	Gandhinagar (3-4)	0	0	0	0	0	2688	2652	0	2585	2550	2510	2514
4	Gandhinagar 5	0	0	0	0	0	2560	2514	2552	2527	2503	2498	2504
5	Wanankori 1-6	0	0	0	0	2774	2440	2362	2479	2524	2552	2565	2588
6	Wanankori 7	2118	2156	2147	2092	2082	2133	2107	2123	2131	2194	2215	2254
7	Wanankori 8	0	0	2449	2471	2493	2475	2459	2427	2404	2448	2396	2399
8	Sikka Extn. (3-4)	3203	3206	3246	3265	3267	3227	3191	3221	3184	3202	4275	3139
9	KLTPS 3	3116	3127	3153	3216	3165	3179	3214	3107	3059	3071	3098	3087
10	KLTPS 4	3319	3158	3168	3265	3653	3653	3121	3059	3185	3232	3060	3069
11	BLTPS 1&2	2700	2060	2014	2076	2230	2169	2088	2110	2054	2550	2529	2700
13	Dhuvaran CCP2	2094	2099	2091	2090	2230	2192	2122	2096	2118	2486	2124	2069
14	Dhuvaran CCP3	1799	1818	0	0	0	1798	1752	1812	1802	0	1792	1834
15	Utran Extension	1819	1755	1706	-	1721	1745	1742	1707	1752	1727	1965	2054
16	Ukai Hydro	-	-	-	-	-	-	-	-	-	-	-	-
17	Kadana Hydro	-	-	-	-	-	-	-	-	-	-	-	-

Sr. No.	Power Station	Auxil. Consumption (%)											
		April	May	June	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	March
1	Ukai (1-5)	10.64%	9.61%	10.55%	17.20%	20.86%	11.83%	10.85%	10.85%	9.77%	9.61%	10.02%	10.06%
2	Ukai Extn. 6	6.25%	6.83%	7.10%	18.64%	8.82%	6.41%	6.21%	6.08%	5.60%	5.95%	6.88%	9.25%
3	Gandhinagar (3-4)	0.00%	0.00%	0.00%	0.00%	0.00%	27.54%	31.68%	36.64%	12.64%	10.90%	9.66%	9.74%
4	Gandhinagar 5	0.00%	0.00%	0.00%	0.00%	0.00%	11.46%	10.46%	12.21%	10.77%	9.47%	9.77%	9.99%
5	Wanankori 1-6	0.00%	0.00%	0.00%	0.00%	0.00%	12.41%	11.20%	11.12%	9.49%	9.20%	9.50%	9.47%
6	Wanankori 7	6.00%	0.00%	0.00%	0.00%	0.00%	16.30%	12.27%	10.40%	9.24%	8.95%	8.40%	8.60%
7	Wanankori 8	4.10%	8.79%	11.16%	5.86%	8.43%	5.93%	4.52%	5.36%	4.78%	4.92%	4.97%	5.76%
8	Sikka Extn. (3-4)	0.00%	0.00%	9.57%	13.35%	13.91%	10.33%	9.84%	9.44%	8.89%	10.64%	9.74%	9.55%
9	KLTPS 3	12.54%	12.22%	12.09%	12.36%	12.96%	12.40%	11.19%	12.11%	12.72%	14.09%	35.43%	11.93%
10	KLTPS 4	19.83%	20.31%	21.94%	25.08%	24.88%	26.73%	31.38%	22.96%	22.11%	24.80%	22.74%	25.03%
11	BLTPS 1&2	22.41%	19.45%	21.73%	23.54%	49.88%	40.40%	23.02%	18.97%	21.07%	24.54%	22.99%	20.90%
12	Dhuvaran CCP1	4.61%	4.61%	4.75%	5.55%	10.35%	8.31%	4.99%	5.63%	5.45%	15.84%	8.48%	17.77%
13	Dhuvaran CCP2	5.45%	5.36%	4.49%	5.04%	7.50%	6.68%	4.68%	5.14%	5.33%	18.69%	9.45%	6.01%
14	Dhuvaran CCP3	2.43%	3.09%	0.00%	0.00%	0.00%	2.74%	2.22%	2.82%	2.75%	25.10%	4.21%	2.84%
15	Utran Extension	2.35%	2.52%	2.11%	2.21%	2.64%	2.47%	2.11%	2.39%	2.51%	7.37%	3.49%	2.99%
16	Ukai Hydro	0.73%	0.76%	0.93%	0.87%	0.67%	0.78%	0.67%	0.78%	0.88%	1.00%	0.68%	0.65%
17	Kadana Hydro	0.82%	0.89%	0.93%	0.85%	0.69%	0.62%	0.85%	0.65%	0.75%	0.59%	0.72%	0.79%

Sr. No.	Power Station	SFC (kg/Kwh)											
		April	May	June	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	March
1	Ukai (1-5)	1.44	0.15	1.10	0.30	10.63	12.71	10.01	3.84	1.84	1.64	6.22	3.17
2	Ukai Extn. 6	1.17	0.40	1.19	11.06	4.09	0.84	0.57	0.18	0.25	0.28	1.13	8.00
3	Gandhinagar (3-4)	0.00	0.00	0.00	0.00	0.00	12.07	10.35	0.00	5.64	2.32	0.00	0.04
4	Gandhinagar 5	0.00	0.00	0.00	0.00	0.00	2.53	0.00	2.91	1.21	0.03	0.19	0.26
5	Wanankori 1-6	0.00	0.00	0.00	0.00	34.40	3.86	0.67	3.57	1.48	1.06	0.80	0.77
6	Wanankori 7	0.00	0.00	0.00	0.00	5.08	2.85	1.78	0.54	0.15	0.14	0.06	0.06
7	Wanankori 8	2.79	4.42	4.83	0.88	0.02	1.84	0.00	0.58	0.33	0.93	0.13	1.61
8	Sikka Extn. (3-4)	0.00	0.00	1.80	3.77	5.97	2.69	0.60	1.46	0.24	5.21	2.41	3.76
9	KLTPS 3	2.94	0.99	6.21	6.07	10.43	2.22	0.45	4.80	1.94	7.17	128.88	1.60
10	KLTPS 4	1.89	3.15	1.60	5.70	4.72	10.69	19.29	5.94	1.66	4.12	4.59	0.00
11	BLTPS 1&2	3.37	0.26	2.99	5.89	42.06	27.34	5.89	2.61	6.19	6.55	8.13	6.77
12	Dhuvaran CCP1	-	-	-	-	-	-	-	-	-	-	-	-
13	Dhuvaran CCP2	-	-	-	-	-	-	-	-	-	-	-	-
14	Dhuvaran CCP3	-	-	-	-	-	-	-	-	-	-	-	-
15	Utran Extension	-	-	-	-	-	-	-	-	-	-	-	-
16	Ukai Hydro	-	-	-	-	-	-	-	-	-	-	-	-
17	Kadana Hydro	-	-	-	-	-	-	-	-	-	-	-	-

Sr. No.	Power Station	Actual Gross Generation (Mw)											
		April	May	June	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	March
1	Ukai (1-5)	89.36	112.99	97.53	1.41	3.20	107.07	184.38	122.75	286.32	323.86	265.22	290.69
2	Ukai Extn. 6	232.75	213.09	139.58	20.9	71.54	249.73	282.54	259.86	283.18	267.27	168.30	145.30
3	Gandhinagar (3-4)	0.00	0.00	0.00	0.00	0.00	8.96	5.07	0.02	40.05	181.59	238.77	268.89
4	Gandhinagar 5	0.00	0.00	0.00	0.00	0.00	61.46	102.00</					