

PERFORMANCE PARAMETER FOR THE MONTH OF APRIL-MAY-JUNE-2021

Sr. No.	Power Station	PAF (%)			PLF (%)			SHR as Fired (Kcal/Kwh)			Auxi. Consumption (%)			SFC (Kg./Kwh)			Actual Gross Generation (Mus)			Net Generation (Mus)		
		April	May	June	April	May	June	April	May	June	April	May	June	April	May	June	April	May	June	April	May	June
1	Ukai (3-5)	65.90%	76.25%	82.35%	57.77%	34.38%	27.74%	2611	2515	2414	10.49%	11.04%	10.69%	4.58	3.11	0.82	253.74	156.05	121.85	227.13	138.83	108.83
2	Ukai Extn. 6	65.42%	72.36%	76.31%	65.54%	71.81%	74.97%	2395	2397	2401	7.01%	6.83%	6.72%	3.72	1.26	1.34	235.93	267.14	269.89	219.40	248.91	251.75
3	Gandhinagar (3-4)	99.19%	99.34%	99.19%	84.41%	15.77%	15.14%	2520	2515	2602	9.82%	12.87%	13.83%	0.26	0.72	7.18	255.26	49.28	45.79	230.18	42.93	39.45
4	Gandhinagar 5	100.00%	100.00%	98.37%	91.11%	47.15%	65.48%	2500	2508	2525	9.95%	11.39%	10.93%	0.00	0.89	2.13	137.76	73.66	99.01	124.05	65.33	88.18
5	Wanakbori 1-6	88.96%	93.02%	92.58%	73.91%	33.04%	25.03%	2553	2515	2456	9.29%	10.01%	10.18%	0.53	0.99	1.48	670.50	309.70	227.07	608.18	278.69	203.96
6	Wanakbori 7	89.93%	97.20%	99.85%	77.25%	44.39%	61.99%	2464	2465	2470	9.20%	9.67%	9.99%	0.94	0.83	0.88	116.81	69.35	93.74	106.06	62.65	84.37
7	Wanakbori 8	77.84%	84.86%	87.46%	74.27%	74.66%	83.21%	2222	2182	2162	4.98%	4.86%	4.63%	0.50	0.85	0.52	427.77	444.40	479.29	406.47	422.80	457.10
8	Sikka Extn. (3-4)	85.37%	85.98%	89.22%	80.16%	40.91%	19.03%	2407	2409	2436	9.20%	10.51%	10.85%	1.66	0.93	3.69	288.56	152.19	68.51	262.03	136.20	61.08
9	KLTPS 3	81.74%	77.39%	78.05%	83.40%	72.73%	80.31%	3159	3244	3236	13.00%	13.61%	13.18%	2.04	7.67	4.82	45.04	40.59	43.37	39.18	35.06	37.65
10	KLTPS 4	40.17%	36.75%	24.89%	45.30%	37.96%	0.79%	3063	3158	4370	26.23%	28.66%	-	2.27	7.11	162.21	24.46	21.18	0.43	18.04	15.11	-1.10
11	BLTPS 1&2	17.09%	18.56%	24.47%	20.01%	22.12%	40.94%	2896	2843	2853	26.43%	24.42%	19.97%	6.98	4.03	3.38	72.03	82.27	147.39	53.00	62.18	117.96
12	Dhuvaran CCPP 1	82.39%	71.18%	73.69%	22.78%	6.41%	12.40%	2130	2482	2292	7.01%	13.98%	8.60%	-	-	-	17.49	5.09	9.52	16.26	4.38	8.70
13	Dhuvaran CCPP 2	75.45%	77.65%	78.93%	23.24%	5.67%	11.98%	2185	2224	2276	6.63%	17.77%	9.49%	-	-	-	18.82	4.74	9.70	17.57	3.90	8.78
14	Dhuvaran CCPP 3	84.45%	93.17%	64.15%	28.57%	1.89%	1.49%	1890	1973	2383	3.68%	20.52%	19.86%	-	-	-	77.38	5.28	4.05	74.53	4.19	3.24
15	Utran Extension	97.81%	96.71%	97.62%	29.62%	6.87%	21.12%	1812	1849	1864	3.41%	7.09%	4.07%	-	-	-	79.89	19.16	56.97	77.17	17.80	54.65
16	Ukai Hydro	97.79%	97.56%	97.43%	32.55%	15.91%	14.02%	-	-	-	0.74%	0.89%	0.90%	-	-	-	71.48	36.11	30.78	70.95	35.79	30.50
17	Kadana Hydro	93.62%	94.49%	94.49%	5.32%	1.88%	2.64%	-	-	-	0.84%	1.00%	0.97%	-	-	-	9.28	3.39	4.60	9.20	3.36	4.56