

PERFORMANCE PARAMETER FOR THE MONTH OF JULY-AUGUST-SEPTEMBER-2021

Sr. No.	Power Station	PAF (%)			PLF (%)			SHR as Fired (Kcal/Kwh)			Auxi. Consumption (%)			SFC (Kg./Kwh)			Actual Gross Generation (Mus)			Net Generation (Mus)		
		JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER
1	Ukai (3-5)	91.44%	69.46%	66.16%	34.58%	58.98%	46.23%	2498	2666	2620	10.99%	10.75%	10.83%	6.95	18.36	13.56	156.93	267.66	203.06	139.68	238.89	181.07
2	Ukai Extn. 6	62.78%	0.00%	0.00%	55.13%	0.00%	0.00%	2411	0	0	7.27%	0.00%	0.00%	3.30	0.00	0.00	205.09	0.00	0.00	190.17	-2.02	-1.51
3	Gandhinagar (3-4)	99.05%	99.49%	82.40%	33.43%	87.59%	71.65%	2537	2520	2581	11.32%	9.89%	10.72%	0.97	0.65	4.79	104.47	273.71	216.67	92.64	246.64	193.43
4	Gandhinagar 5	12.56%	0.00%	0.00%	10.99%	0.00%	0.00%	2506	0	0	14.72%	0.00%	0.00%	0.17	0.00	0.00	17.17	0.00	0.00	14.65	-0.52	-0.66
5	Wanakbori 1-6	79.90%	54.51%	33.42%	26.24%	45.25%	21.98%	2501	2571	2566	10.10%	9.77%	11.34%	1.22	3.45	6.97	246.02	424.22	199.39	221.16	382.76	176.77
6	Wanakbori 7	87.13%	90.51%	73.73%	62.67%	82.62%	53.97%	2476	2480	2539	10.19%	10.03%	11.98%	1.39	2.41	4.92	97.91	129.09	81.60	87.93	116.15	71.82
7	Wanakbori 8	95.00%	68.94%	63.05%	81.80%	66.14%	59.20%	2222	2242	2285	4.67%	5.22%	6.40%	0.07	2.56	5.39	486.90	393.68	341.00	464.16	373.13	319.19
8	Sikka Extn. (3-4)	99.43%	89.01%	21.77%	48.36%	67.54%	6.02%	2408	2420	2688	9.55%	9.19%	23.82%	0.02	1.48	22.38	179.91	251.26	21.68	162.73	228.18	16.52
9	KLTPS 3	62.39%	69.64%	69.67%	63.34%	70.15%	70.73%	3285	3261	3312	13.99%	13.84%	14.11%	9.11	6.89	11.80	35.34	39.15	38.20	30.40	33.73	32.81
10	KLTPS 4	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	0.00	0.00	0.00	0.00	0.00	0.00	-0.04	-0.37	-0.42
11	BLTPS 1&2	39.26%	38.47%	19.51%	42.79%	40.52%	23.02%	2827	2972	3083	18.66%	17.09%	25.60%	1.64	2.95	12.44	159.18	150.74	82.87	129.47	124.97	61.65
12	Dhuvaran CCPP 1	76.64%	63.99%	84.94%	11.52%	16.48%	0.04%	2235	2136	9815	10.57%	8.20%	0.00%	-	-	-	9.14	13.08	0.03	8.17	12.00	-0.37
13	Dhuvaran CCPP 2	79.14%	59.30%	83.37%	14.16%	15.29%	0.00%	2283	2163	0	8.49%	8.70%	0.00%	-	-	-	11.85	12.79	0.00	10.84	11.68	-0.67
14	Dhuvaran CCPP 3	59.43%	58.93%	63.62%	4.97%	16.26%	0.18%	2420	1907	5047	11.22%	4.76%	136.74%	-	-	-	13.89	45.49	0.48	12.33	43.32	-0.18
15	Utran Extension	68.83%	79.97%	98.73%	10.10%	24.94%	4.80%	1840	1776	2088	5.18%	3.32%	9.83%	-	-	-	28.16	69.52	12.95	26.70	67.21	11.68
16	Ukai Hydro	96.32%	96.32%	96.32%	8.78%	6.35%	56.83%	-	-	-	1.13%	1.39%	0.62%	-	-	-	19.91	14.41	124.79	19.69	14.21	124.02
17	Kadana Hydro	79.98%	86.77%	90.49%	11.96%	7.19%	10.94%	-	-	-	0.84%	0.80%	0.67%	-	-	-	21.53	12.95	19.06	21.35	12.84	18.93