

PERFORMANCE PARAMETER FOR THE MONTH OF JANUARY-FEBRUARY-MARCH-2022

Sr. No.	Power Station	PAF (%)			PLF (%)			SHR as Fired (Kcal/Kwh)			Auxi. Consumption (%)			SFC (Kg./Kwh)			Actual Gross Generation (Mus)			Net Generation (Mus)		
		JANUARY	FEBRUARY	MARCH	JANUARY	FEBRUARY	MARCH	JANUARY	FEBRUARY	MARCH	JANUARY	FEBRUARY	MARCH	JANUARY	FEBRUARY	MARCH	JANUARY	FEBRUARY	MARCH	JANUARY	FEBRUARY	MARCH
1	Ukai (3-5)	60.53%	78.06%	73.92%	52.26%	74.18%	72.39%	2626	2648	2654	10.05%	9.48%	9.39%	4.14	7.14	2.16	237.19	304.08	328.52	213.34	275.25	297.68
2	Ukai Extn. 6	76.33%	81.36%	85.15%	72.61%	77.17%	83.21%	2415	2401	2374	7.79%	6.29%	6.08%	1.05	1.01	0.31	270.11	259.28	309.56	249.07	242.97	290.72
3	Gandhinagar (3-4)	97.78%	98.97%	89.78%	76.92%	88.83%	82.36%	2556	2539	2542	9.88%	9.49%	9.91%	0.93	0.11	0.97	240.37	250.72	257.35	216.62	226.94	231.85
4	Gandhinagar 5	92.12%	99.52%	99.98%	81.43%	92.45%	93.93%	2523	2505	2503	10.39%	9.93%	9.89%	1.12	0.00	0.00	127.23	130.46	146.75	114.01	117.51	132.24
5	Wanakbori 1-6	64.71%	72.00%	66.45%	56.12%	68.76%	63.54%	2616	2598	2639	10.48%	9.91%	10.14%	2.55	2.14	4.56	526.05	582.17	595.68	470.93	524.49	535.28
6	Wanakbori 7	77.32%	89.60%	90.25%	61.64%	77.73%	77.32%	2499	2482	2489	10.25%	9.45%	9.82%	0.46	0.11	1.08	96.31	109.69	120.81	86.43	99.33	108.94
7	Wanakbori 8	75.08%	40.37%	75.23%	67.59%	37.16%	70.21%	2235	2252	2211	5.12%	6.80%	4.95%	0.64	3.12	0.71	402.30	199.79	417.88	381.68	186.21	397.19
8	Sikka Extn. (3-4)	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	0.00	0.00	0.00	0.00	0.00	0.00	-0.93	-0.78	-0.93
9	KLTPS 3	66.32%	51.22%	49.64%	64.62%	51.99%	50.20%	3267	3284	3376	13.63%	13.87%	14.67%	8.72	8.95	17.93	36.06	26.20	28.01	31.14	22.52	23.90
10	KLTPS 4	0.00%	0.00%	4.57%	0.00%	0.00%	5.34%	0	0	3597	0.00%	0.00%	0.00%	0.00	0.00	50.81	0.00	0.00	2.98	-0.38	-0.32	0.80
11	BLTPS 1&2	42.69%	40.20%	33.82%	45.15%	43.54%	37.78%	2988	3031	3043	17.17%	17.81%	19.06%	1.29	2.59	3.03	167.94	146.29	140.55	139.10	120.24	113.77
12	Dhuvaran CCPP 1	91.88%	92.82%	67.44%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.17	-0.23	-0.21
13	Dhuvaran CCPP 2	90.76%	90.76%	67.13%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.27	-0.30	-0.29
14	Dhuvaran CCPP 3	0.00%	9.07%	73.85%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.31	-0.17	-0.68
15	Utran Extension	99.99%	99.99%	76.26%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.64	-0.62	-0.70
16	Ukai Hydro	73.85%	73.69%	76.93%	1.64%	30.53%	21.88%	-	-	-	4.79%	0.74%	0.80%	-	-	-	3.72	62.57	49.66	3.54	62.10	49.26
17	Kadana Hydro	70.72%	69.77%	66.95%	13.82%	14.19%	13.03%	-	-	-	0.71%	0.90%	0.82%	-	-	-	24.88	23.08	23.47	24.71	22.87	23.27