

## PERFORMANCE PARAMETER FOR THE MONTH OF APRIL-MAY-JUNE-2022

Sr. No.	Power Station	PAF (%)			PLF (%)			SHR as Fired (Kcal/Kwh)			Auxi. Consumption (%)			SFC (ml./Kwh)			Actual Gross Generation (Mus)			Net Generation (Mus)		
		April	May	June	April	May	June	April	May	June	April	May	June	April	May	June	April	May	June	April	May	June
		1	Ukai (3-5)	76.12%	63.41%	67.39%	76.24%	63.51%	68.45%	2643	2653	2653	9.18%	9.76%	10.08%	4.35	9.48	7.25	334.83	288.24	300.65	304.10
2	Ukai Extn. 6	93.76%	67.27%	72.66%	92.79%	67.14%	72.91%	2345	2392	2402	6.13%	6.84%	6.75%	0.24	1.45	3.37	334.05	249.77	262.48	313.58	232.69	244.77
3	Gandhinagar (3-4)	95.10%	76.21%	79.28%	91.66%	70.88%	76.65%	2534	2564	2591	10.00%	10.79%	10.76%	0.63	0.84	2.16	277.19	221.48	231.79	249.48	197.58	206.84
4	Gandhinagar 5	94.55%	95.45%	78.17%	92.38%	89.25%	76.93%	2507	2521	2557	10.03%	10.42%	11.01%	0.39	0.44	2.90	139.69	139.45	116.31	125.67	124.91	103.51
5	Wanakbori 1-6	73.87%	71.84%	64.38%	78.76%	67.10%	60.77%	2619	2624	2644	9.53%	10.05%	10.39%	4.60	5.12	2.71	714.52	629.05	551.30	646.41	565.82	494.03
6	Wanakbori 7	90.78%	73.54%	97.90%	84.45%	64.54%	85.42%	2471	2491	2479	9.87%	10.04%	9.63%	1.12	1.26	0.64	127.69	100.84	129.15	115.09	90.71	116.71
7	Wanakbori 8	81.77%	89.66%	58.92%	79.86%	84.39%	55.79%	2211	2211	2243	4.84%	4.87%	5.71%	0.87	0.00	1.52	459.99	502.27	321.37	437.74	477.80	303.01
8	Sikka Extn. (3-4)	12.95%	97.48%	97.53%	10.36%	37.79%	39.90%	2607	2565	2531	12.43%	10.62%	10.41%	9.55	2.49	2.80	37.28	140.57	143.65	32.65	125.65	128.69
9	KLTPS 3	66.04%	42.14%	7.43%	66.99%	42.69%	7.12%	3586	4058	4583	14.34%	14.98%	24.99%	21.16	20.25	79.77	36.18	23.82	3.85	30.99	20.25	2.88
10	KLTPS 4	41.36%	74.73%	74.55%	45.84%	79.04%	78.66%	3207	3680	3716	24.76%	18.30%	0.18	2.40	0.42	0.00	24.75	44.10	42.47	18.62	36.03	34.71
11	BLTPS 1&2	33.32%	31.66%	27.09%	36.83%	35.05%	31.06%	3020	3043	2980	19.07%	19.62%	21.06%	4.93	3.70	4.49	132.57	130.37	111.82	107.29	104.79	88.27
12	Dhuvaran CAPP 1	73.30%	92.82%	92.82%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.24	-0.18	-0.16
13	Dhuvaran CAPP 2	68.64%	90.76%	90.76%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.42	-0.29	-0.26
14	Dhuvaran CAPP 3	78.81%	100.00%	100.00%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.41	-0.72	-0.58
15	Utran Extension	100.00%	100.00%	100.00%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.69	-0.71	-0.67
16	Ukai Hydro	78.69%	96.32%	96.32%	31.29%	23.71%	13.22%	-	-	-	0.72%	0.77%	0.95%	-	-	-	68.71	53.80	29.03	68.21	53.39	28.75
17	Kadana Hydro	62.14%	59.12%	66.69%	4.94%	4.46%	5.25%	-	-	-	1.28%	0.80%	0.81%	-	-	-	8.61	8.03	9.15	8.50	7.96	9.07