

PERFORMANCE PARAMETER FOR THE MONTH OF JULY-AUGUST-SEPTEMBER-2022

Sr. No.	Power Station	PAF (%)			PLF (%)			SHR as Fired (Kcal/Kwh)			Auxi. Consumption (%)			SFC (ml./Kwh)			Actual Gross Generation (Mus)			Net Generation (Mus)		
		JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER	JULY	AUGUST	SEPTEMBER
1	Ukai (3-5)	36.79%	47.10%	45.50%	35.44%	44.45%	44.01%	2789	2703	2660	11.49%	11.65%	11.65%	18.43	27.72	29.37	160.85	201.73	193.31	142.36	178.24	170.79
2	Ukai Extn. 6	58.22%	31.92%	42.21%	58.44%	33.29%	44.11%	2469	2527	2583	7.73%	9.57%	9.25%	25.14	20.99	37.86	217.38	123.85	158.81	200.57	112.00	144.12
3	Gandhinagar (3-4)	48.46%	61.49%	63.82%	46.66%	41.30%	55.13%	2610	2640	2663	11.13%	11.95%	11.97%	6.26	18.45	15.84	145.81	129.05	166.70	129.58	113.63	146.76
4	Gandhinagar 5	52.51%	44.59%	49.50%	54.89%	47.50%	50.63%	2696	2812	2709	12.80%	14.04%	13.52%	22.22	55.44	23.14	85.76	74.22	76.55	74.78	63.79	66.20
5	Wanakbori 1-6	60.81%	46.36%	33.30%	50.31%	39.89%	32.10%	2643	2711	2774	10.51%	11.36%	12.05%	7.78	14.18	20.70	471.64	373.91	291.24	422.06	331.42	256.16
6	Wanakbori 7	92.89%	78.42%	68.54%	76.33%	70.27%	64.32%	2518	2567	2599	11.03%	11.66%	11.95%	2.52	7.56	9.80	119.25	109.79	97.26	106.10	96.99	85.63
7	Wanakbori 8	0.00%	35.10%	48.21%	0.00%	31.14%	48.30%	0	2257	2248	0.00%	9.26%	9.34%	0.00	10.07	4.73	0.00	185.36	278.19	-1.83	171.67	259.87
8	Sikka Extn. (3-4)	99.56%	94.68%	95.75%	14.27%	37.92%	66.35%	2742	2603	2557	16.35%	10.33%	9.51%	15.96	2.69	0.62	53.10	141.08	238.87	44.42	126.51	216.16
9	KLTPS 3	10.43%	68.99%	69.69%	9.89%	71.30%	69.28%	4664	3513	3646	25.94%	14.07%	13.72%	117.23	22.99	15.52	5.52	39.79	37.41	4.09	34.19	32.28
10	KLTPS 4	20.54%	13.14%	53.62%	20.96%	14.13%	57.93%	4123	3943	3689	35.31%	51.24%	22.64%	34.40	53.66	2.49	11.70	7.88	31.28	7.57	3.84	24.20
11	BLTPS 1&2	15.58%	10.38%	19.65%	19.41%	12.79%	23.54%	3143	3071	3037	29.51%	30.35%	25.17%	9.50	3.35	4.31	72.21	47.57	84.73	50.90	33.13	63.41
12	Dhuvaran CCPP 1	92.82%	92.82%	92.82%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.25	-0.27	-0.29
13	Dhuvaran CCPP 2	90.76%	87.83%	90.76%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.41	-0.39	-0.45
14	Dhuvaran CCPP 3	100.00%	100.00%	100.00%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.71	-0.72	-0.56
15	Utran Extension	100.00%	100.00%	100.00%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.69	-0.67	-0.69
16	Ukai Hydro	91.01%	96.32%	96.32%	42.48%	100.37%	62.23%	-	-	-	0.66%	0.60%	0.64%	-	-	-	96.39	227.75	136.65	95.75	226.39	135.78
17	Kadana Hydro	53.77%	61.03%	85.14%	14.63%	38.42%	55.11%	-	-	-	0.77%	0.63%	0.61%	-	-	-	26.35	69.18	96.02	26.15	68.75	95.43