

## PERFORMANCE PARAMETER FOR THE MONTH OF OCTOBER-NOVEMBER-DECEMBER-2022

Sr. No.	Power Station	PAF (%)			PLF (%)			SHR as Fired (Kcal/Kwh)			Auxi. Consumption (%)			SFC (ml./Kwh)			Actual Gross Generation (Mus)			Net Generation (Mus)		
		OCT.	NOV.	DEC.	OCT.	NOV.	DEC.	OCT.	NOV.	DEC.	OCT.	NOV.	DEC.	OCT.	NOV.	DEC.	OCT.	NOV.	DEC.	OCT.	NOV.	DEC.
1	Ukai (3-5)	52.83%	53.32%	33.95%	54.19%	54.07%	44.54%	2681	2681	2644	11.03%	10.92%	10.76%	23.42	22.85	11.08	245.93	237.49	202.14	218.82	211.55	180.39
2	Ukai Extn. 6	50.16%	58.76%	55.76%	52.03%	58.83%	56.48%	2532	2478	2512	8.16%	7.24%	7.46%	6.70	2.52	3.75	193.56	211.78	210.11	177.76	196.46	194.43
3	Gandhinagar (3-4)	91.88%	86.64%	67.65%	70.68%	80.42%	68.01%	2576	2582	2619	10.78%	10.66%	10.76%	2.85	2.34	12.31	220.85	243.18	212.53	197.05	217.26	189.65
4	Gandhinagar 5	93.77%	56.91%	70.65%	83.68%	58.38%	72.91%	2562	2626	2634	10.77%	12.31%	11.46%	1.61	3.68	8.01	130.74	88.28	113.92	116.66	77.41	100.86
5	Wanakbori 1-6	40.77%	41.64%	38.41%	36.67%	40.04%	36.29%	2743	2698	2665	11.00%	10.74%	10.87%	17.66	13.39	7.49	343.74	363.27	340.20	305.92	324.24	303.21
6	Wanakbori 7	69.10%	22.25%	54.26%	63.15%	21.23%	47.42%	2630	2645	2531	11.57%	12.05%	10.89%	12.99	14.95	5.90	98.67	32.11	74.09	87.25	28.24	66.02
7	Wanakbori 8	75.43%	84.72%	63.54%	69.07%	77.75%	56.38%	2201	2193	2192	4.95%	4.44%	5.44%	1.92	1.15	1.39	411.08	447.82	335.55	390.74	427.92	317.28
8	Sikka Extn. (3-4)	83.24%	89.85%	98.90%	45.45%	37.39%	39.48%	2591	2694	2641	10.91%	11.25%	10.36%	0.49	4.12	1.32	169.09	134.59	146.88	150.65	119.45	131.67
9	KLTPS 3	81.09%	47.74%	59.86%	80.49%	48.76%	60.69%	3535	3512	3520	13.62%	14.10%	13.81%	4.02	7.57	9.43	44.92	26.33	33.86	38.80	22.62	29.19
10	KLTPS 4	34.19%	48.41%	27.54%	37.18%	50.67%	29.07%	3691	3697	3636	25.95%	22.18%	29.50%	4.30	6.07	10.70	20.75	27.36	16.22	15.36	21.29	11.44
11	BLTPS 1&2	20.72%	15.17%	35.17%	24.81%	17.04%	38.92%	3062	3038	2948	25.59%	23.88%	18.50%	9.00	6.50	1.50	92.28	61.33	144.77	68.67	46.68	117.99
12	Dhuvaran CCPP 1	92.82%	92.82%	94.64%	0.00%	0.00%	0.00%	-	-	-	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.28	-0.17	-0.11
13	Dhuvaran CCPP 2	90.76%	87.74%	92.48%	0.00%	0.00%	0.00%	-	-	-	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.39	-0.25	-0.19
14	Dhuvaran CCPP 3	100.00%	100.00%	100.00%	0.00%	0.00%	0.00%	-	-	-	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.59	-0.47	-0.23
15	Utran Extension	100.00%	100.00%	100.00%	0.00%	0.00%	0.00%	-	-	-	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.70	-0.70	-0.71
16	Ukai Hydro	96.32%	96.30%	96.32%	69.50%	23.99%	21.49%	-	-	-	0.63%	0.77%	0.80%	-	-	-	157.70	52.69	48.76	156.71	52.28	48.37
17	Kadana Hydro	94.54%	94.75%	95.47%	18.15%	8.68%	13.20%	-	-	-	0.69%	0.85%	0.82%	-	-	-	32.68	15.13	23.77	32.45	15.00	23.58